



# Procedure to replace concrete baffle

**Clermont County  
Public Health**  
Prevent. Promote. Protect.

2275 Bauer Road, Suite 300 Batavia, OH 45103

*Fact Sheet*

**How to replace broken concrete baffle when less than one inch of PVC pipe extends into the tank**

## **PVC pieces needed for repair**

- 1 - 4" schedule 40 PVC sanitary tee
- 1 - 4" schedule 40 PVC, 3-4 inches in length
- 2 - 3" schedule 40 coupling, ridges and high spots on exterior to be smoothed
- 1 - 3" schedule 40 PVC, 4 inches in length

